



TO BE INSTALLED, INSPECTED, MAINTAINED AND TESTED IN ACCORDANCE WITH THE STANDARD FOR PORTABLE FIRE EXTINGUISHERS, NFPA-10.

WARNING
IMPORTANT SAFETY INFORMATION TO LESSEN RISK OF PERSONAL INJURY - CONTENTS UNDER PRESSURE DO NOT PUNCTURE OR INCINERATE EXTINGUISHER. DO NOT USE EXTINGUISHER IF DAMAGED OR CORRODED - START DISCHARGE FROM PROPER DISTANCE TO AVOID SPLASHING OR SCATTERING OF BURNING MATERIAL - DO NOT EXPOSE TO TEMPERATURES ABOVE 120°F (49°C) - DO NOT DISCHARGE DIRECTLY INTO FACE - USE ONLY AS A FIRE EXTINGUISHER - KEEP AWAY FROM CHILDREN - REFER TO ANSUL MSDS FOR ADDITIONAL AGENT INFORMATION

AFTER USING
RECHARGE EXTINGUISHER IMMEDIATELY AFTER ANY USE. PARTIAL DISCHARGE MAY CAUSE EXTINGUISHER TO LEAK. INVERT EXTINGUISHER AND PRESS OPERATING LEVER TO RELEASE ALL REMAINING PRESSURE. HAVE EXTINGUISHER RECHARGED BY AN ANSUL AUTHORIZED DISTRIBUTOR IN ACCORDANCE WITH INSTRUCTION MANUAL, FORM NO. F-83171. FILL ONLY WITH DRY CHEMICAL MANUFACTURED BY ANSUL AND PRESURE TO 165 PSI (13.44 bar) WITH NITROGEN AT 70°F (21.1°C)

INSPECTION
INSPECT MONTHLY OR MORE FREQUENTLY WHEN DISCHARGED. REQUIRE BE SURE HOSE AND/OR NOZZLE IS UNOBSTRUCTED, PULL PIN AND VISUAL OPERATING RANGE. CHECK UNIT FOR DAMAGE OR CORROSION.

MAINTENANCE
MAINTENANCE SHALL BE PERFORMED ANNUALLY OR EARLIER WHEN SPECIFICALLY INDICATED BY AN INSPECTION DISCREPANCY. MAINTENANCE OR REPAIR SHOULD BE PERFORMED BY AN ANSUL AUTHORIZED DISTRIBUTOR IN ACCORDANCE WITH INSTRUCTION MANUAL, FORM NO. F-83171. TOTAL CHARGED WEIGHT SHALL BE 14.02 (6.35 kg) MINIMUM TO 16.13 (7.32 kg) MAXIMUM.

ANSUL FACTORY CREATED
100 STANTON STREET
MANASSAS, VA 20108-2542
715-735-7411

INSTRUCTIONS

1. PULL PIN, HOLD UPRIGHT.
2. START BACK 10 FEET (3 M), AIM AT BASE OF FIRE.
3. DEPRESS PUSH LEVER, SWEEP SIDE TO SIDE.



ANSUL Sensa